

Pick FYIO

MISSISSIPPI DEPARTMENT OF TRANSPORTATION

Inter-Departmental Memorandum

TO: Mr. Thomas C. Russell
State Construction Engineer

DATE: April 25, 2000

FROM: John Pickering *J.B.P.*
Roadway Design Div. Engineer

SUBJECT OR PROJECT NO: 59-0055-02-117-10

INFORMATION COPY TO:

COUNTY: Madison

RWD Hydraulic Section
RWD file (via Reeves)

Roadway Design Division staff has reviewed the drawings sent with the request to use precast inlets on the above captioned project for the curb inlets, median inlets and round manholes. After reviewing these drawings and comparing them to the drawings on file in Roadway Design, our position is that the precast structures can be substituted for the inlets and manhole as shown in Roadway Design's Standard Drawings

Any approval for the use of precast inlets is to be a "one-time" approval only. Any future requests are to be approved on a case by case basis.

If you have any questions, please advise.

Attachment
JBP/swr