

Questions and Answers, Part 1 – Soil Nail Retaining Walls on the D’Iberville Interchange project

Date: November 30, 2012

Project Number: NHS-0010-01(144)/105281-301000

County: Harrison County

Project Description: Provide all services and materials to design and construct permanent soil nail retaining walls on the D’Iberville Interchange project – Harrison County.

Dates Published in Clarion Ledger: November 21st and 28th, 2012

From: Scot Ehrgott, P.E. – MDOT Director of Consultant Services

Question #1: We were wondering what the surface area quantities are for the permanent soil nail shotcrete wall on this project. Can you provide us with conceptual drawings or estimated area and budget for this wall?

Answer: The items requested are not available for distribution; however, the approximate height of the wall is 20 feet tall and the approximate length of wall is 336 feet long. The approximate square footage is 4660 square feet or 518 square yards. The wall will be trapezoidal in shape so the length cannot be multiplied by the width to get the approximate area of the wall.